




KOHLER ROMAN, LLC
CONSULTING FINANCIALS

301 Main Street, Danbury, CT 06810
203 / 778-1017 F 203 / 778-1016
1370 Broadway, New York, NY 10018
212-865-2422 F 212-865-2423
www.kohlerroman.com
Email: krc@kohlerroman.com



301 Main Street, Danbury, CT 06810
203.778.1017 F 203.778.1018
1370 Broadway, New York, NY 10018
212.695.2422 F 212.695.2423
www.kohlertronan.com
E-mail: ktrce@kohlertronan.com

DRAWN BY:	AC	DRAWING
CHECKED BY:	KC	
SCALE:	1/4" = 1'-0"	
DATE:	07/07/11	

FP202



BACKFLOW PREVENTER SIZE	MAXIMUM RELIEF VALVE DISCHARGE RATE	DRAIN SIZE
1/4", 3/8", 1/2"	35 GPM	3"
3/4", 1"	140 GPM	6"
1-1/4", 1-1/2", 2"	350 GPM	8"
2-1/2", 3"	500 GPM	8"
4", 6", 8", 10"	800 GPM	10"




1 BACKFLOW PREVENTER DETAIL (2" AND SMALLER)

FP202 / NOT TO SCALE


2 BACKFLOW PREVENTER OVERFLOW PIPING DETAIL

NOT TO SCALE / P202



4 SITE PLAN

HP202 NOT TO SCALE



3 FIRE PUMP TANK DETAIL

FP202 / NOT TO SCALE

5 FIRE PUMP HOUSE

FP202 / NOT TO SCALE

DETAILS & SITE PLAN - FIRE PROTECTION

DRAWN BY:	AC	DRAWING
CHECKED BY:	KC	
SCALE:	1/4" = 1'-0"	
DATE:	07/07/11	

FP202